

FERNHILL CAMPUS

SAMPLE DATE	FLOOR	DRAWS	OUTLET TYPE	OUTLET DESCRIPTION	LEAD RESULTS (PPB)	RL (PPB)
12/6/19	1	1	KI	KITCHEN	ND	1.00
12/6/19	1	2	KI	KITCHEN	ND	1.00
12/6/19	1	1	TC	TEACHER CAFÉ SINK	ND	1.00
12/6/19	1	2	TC	TEACHER CAFÉ SINK	ND	1.00
12/6/19	1	1	BB	BOYS BATHROOM 111	ND	1.00
12/6/19	1	2	BB	BOYS BATHROOM 111	ND	1.00
12/6/19	1	1	GB	GIRLS BATHROOM 111	ND	1.00
12/6/19	1	2	GB	GIRLS BATHROOM 111	5.19	1.00
12/6/19	1	1	MO	NURSE SINK	ND	1.00
12/6/19	1	2	MO	NURSE SINK	ND	1.00
12/6/19	1	1	B	WATER FOUNTAIN ACROSS FROM108	ND	1.00
12/6/19	1	2	B	WATER FOUNTAIN ACROSS FROM108	ND	1.00
12/6/19	1	1	B	WATER FOUNTAIN OUTSIDE GYM	ND	1.00
12/6/19	1	2	B	WATER FOUNTAIN OUTSIDE GYM	ND	1.00
12/6/19	1	1	B	WATER FOUNTAIN ACROSS FROM107	ND	1.00
12/6/19	1	2	B	WATER FOUNTAIN ACROSS FROM107	ND	1.00
12/6/19	1	1	CR	SCIENCE ROOM	ND	1.00
12/6/19	1	2	CR	SCIENCE ROOM	ND	1.00
12/6/19	1	1	CR	ART ROOM	ND	1.00
12/6/19	1	2	CR	ART ROOM	ND	1.00
12/6/19	1	1	CR	CLASSROOM 108	ND	1.00
12/6/19	1	2	CR	CLASSROOM 108	ND	1.00
12/4/19	1	1	WP	WATER PUMP	16.4	1.00
12/4/19	1	2	WP	WATER PUMP	2620	50.0

AWBURY CAMPUS

SAMPLE DATE	FLOOR	DRAWS	OUTLET TYPE	OUTLET DESCRIPTION	LEAD RESULTS (PPB)	RL (PPB)
12/3/19	1	1	KI	KITCHEN HANDWASH SINK BACKDOOR	ND	1.00
12/3/19	1	2	KI	KITCHEN	ND	1.00
12/3/19	1	1	KI	KITCHEN FRONT DOOR SINK	ND	1.00
12/3/19	1	2	KI	KITCHEN	ND	1.00
12/3/19	1	1	KI	KITCHEN HANDWASH BY FRIDGE	ND	1.00
12/3/19	1	2	KI	KITCHEN	ND	1.00
12/3/19	1	1	B	GYM WATERFOUNTAIN	ND	1.00
12/3/19	1	2	B	GYM WATERFOUMTAIN	ND	1.00
12/3/19	1	1	MO	NURSE SINK	ND	1.00
12/3/19	1	2	MO	NURSE SINK	ND	1.00
12/3/19	1	1	CF	CAFETERIA SINK	ND	1.00
12/3/19	1	2	CF	CAFETERIA SINK	ND	1.00
12/3/19	1	1	B	WATER FOUNTAIN 1 ST FLOOR OUTSIDE BATHROOMS	ND	1.00
12/3/19	1	2	B	WATER FOUNTAIN 1 ST FLOOR OUTSIDE BATHROOMS	ND	1.00
12/3/19	2	1	B	WATER FOUNTAIN 2 ND FLOOR OUTSIDE BATHROOM	ND	1.00
12/3/19	2	2	B	WATER FOUNTAIN 2 ND FLOOR OUTSIDE BATHROOM	ND	1.00
12/3/19	1	1	WP	WATER PUMP	ND	1.00
12/3/19	1	2	WP	WATER PUMP	ND	1.00

AA=ABOVE ACTION LIMIT OF 10 PPB

BA= BELOW ACTION

PPB= PARTS PER BILLION

RL= REPORTING LIMIT

ND= INDICATES THAT THE ANALYTE WAS NOT DETECTED AT THE REPORTING LIMIT